



---

NORTH DUPAGE SPECIAL EDUCATION COOPERATIVE

Jim T. Nelson  
Executive Director

**To:** Jim Nelson  
**From:** Reiley Straub  
**Date:** October 2, 2017  
**Re:** Water Testing

---

Suburban Laboratories, Inc. (SLI) located in Geneva, Illinois has been providing independent environmental analytical testing for over 45 years. SLI tests public and private drinking water for municipal and commercial customers. They also do environmental testing related to waste and landfills, product and material testing, and soil/ground and waste water testing.

On September 12, 2017, 6 water samples were taken from 3 different water fountains or faucets and brought to SLI for lead testing. Samples were drawn from units that provided drinking water to students and staff or were used to wash dishes at Lincoln Academy.

I have attached the complete report to this memo for review. I am happy to report that SLI did not find any traces of lead in the samples. The total cost for the testing was \$153.

# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
Fax (708) 544-8587  
www.suburbanlabs.com

September 25, 2017

Reiley Straub  
North DuPage Special Education Cooperative  
132 E Pine Ave  
Roselle, IL 60172

**Workorder: 1709842**

TEL:  
FAX:  
RE: Drinking Water Lead Analysis

Dear Reiley Straub:

Suburban Laboratories, Inc. received 6 sample(s) on 9/12/2017 for the analyses presented in the following report.

Customer has provided 250 mL volume sample bottles for all samples collected. Please note, all sample results that exceed 5.00 ug/L should be promptly reported to parents or guardians of all enrolled students. Results that are below 5.00 ug/L should be reported on the school website. Please refer to Public Act 099-0922 or the Illinois Department of Public Health for specific reporting requirements. Suburban Laboratories will forward all results to the IDPH within seven (7) business days from the date of this report.

This report may not be reproduced, except in full, without the prior written approval of Suburban Laboratories, Inc. If you have any questions regarding these test results, please call me at (708) 544-3260.

Sincerely,



Pat Rodriguez  
Project Manager  
708-544-3260 ext 214  
pat@suburbanlabs.com



# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
Fax (708) 544-8587  
www.suburbanlabs.com

**Report Date:** September 25, 2017

**Workorder:** 1709842

**Client ID:** North DuPage Special Education Cooperative

**Project Name:** Drinking Water Lead Analysis

**Analyte:** Lead

**Method:** EPA 200.8

**Matrix:** Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1709842-001A	Kitchen Sink 1	ND	2.00	µg/L	09/11/17 17:00	9/12/2017	9/20/2017
1709842-002A	Kitchen Sink 2	ND	2.00	µg/L	09/11/17 17:00	9/12/2017	9/20/2017
1709842-003A	drinking ftn 1	ND	2.00	µg/L	09/11/17 17:00	9/12/2017	9/20/2017
1709842-004A	drinking ftn 2	ND	2.00	µg/L	09/11/17 17:00	9/12/2017	9/20/2017
1709842-005A	hallway sink 1	ND	2.00	µg/L	09/11/17 17:00	9/12/2017	9/20/2017
1709842-006A	hallway sink 2	ND	2.00	µg/L	09/11/17 17:00	9/12/2017	9/20/2017